

EXIST PANEL 'P1B' (SECT 2) LOCATION: ELECTRICAL RM #134 RECESSED MOUNTED
 120/208 VOLTS 3 PHASE 4 WIRE 400 AMP. BUS -- A.I.C. SERIES RATED
 MAIN LUGS ONLY CIRCUIT BREAKER TYPE

CKT. NO.	TRIP AMPS	NO. POLE	LOAD SERVED	LOAD- V. A.			LOAD SERVED	NO. POLE	TRIP AMPS	CKT. NO.
				Aø	Bø	Cø				
1	20	1	NEW OVERHEAD DOOR - RM 127 (EXTERIOR)	1100 250			NEW EF-7	1	20	2
3	20	1	NEW OVERHED DOOR - RM 127 (INTERIOR)		1100 250		NEW EF-6	1	20	4
5	20	1	NEW OVERHEAD DOOR - RM 121			1100 540	NEW RTU RECEPTS	1	20	6
7	20	1	NEW OVERHEAD DOOR - RM 138	1100 700			NEW UH-1	1	20	8
9	20	1	- - - SPACE - - -		1040		NEW GWH-1/P-1	1	20	10
11	20	1	- - - SPACE - - -			300	NEW VAV-1, 2, 3	1	20	12
13	20	1	---	900			NEW EF-9	3	20	14
15	20	1	---		900					16
17	20	1	---			900				18
19	20	1	---	---			---	1	20	20
21	20	1	- - - SPACE - - -		---		---	1	20	22
23	20	1	- - - SPACE - - -			---	---	1	20	24
25	30	2	EXIST RESTROOM WATER HEATER	2250 ---			---	1	20	26
27					2250 ---		---	1	20	28
29	20	1	---			---	---	1	20	30
31	20	1	---	---			---	1	20	32
33	20	1	---		---		---	1	20	34
35	20	1	EXIST SPRINKLER RM RECEPT			180 ---	---	1	20	36
37	20	1	---	---			---	1	20	38
39	20	1	---		---		---	1	20	40
41	20	1	---			---	---	1	20	42
				6300	5540	3020				

PROVIDE NEW BREAKER

DESCRIPTION: ADDENDUM #4 - COMPRESSOR EXHAUST

PROPOSAL REQUEST: -

DRAWING NUMBER: E6.3

PROJECT: ECC

SUPPLEMENTAL DRAWING - 5



6304 E. Independence Dr.
 Union, Missouri 63084
 638-084-0540 (ext.)
 638-084-0812 (fax)
 mail@cochranseng.com

• Civil Engineering
 • Land Surveying
 • Architecture
 • Site Development
 • General Consulting
 • Master Planning

DATE BY: RAB DATE: 02/17/16 PLOT BY: 15-6038