

BULLETIN ADDENDUM 03

Date Issued: February 24, 2025

Project Name: ECC Respiratory Care – Union Campus

Project Number/Phase: 24-3465.00/BN

Prepared By: David Wolff, Sophia Stone

Distribution: Ryan Wilson, Amy Miller (Navigate)
Jon Bauer, Robyn Walter, Nancy Mitchell, Karen Hayes (ECC)
Mason Ryan, Jason Heisler, Tim Filiatreau (IMEG)
Alexis Rains, Chrissy Rogers (Arcturis)

Please note the following changes and/or clarifications to the original Construction Documents dated 01/30/25:

Heading Number 1 – Project Manual

Item	Section	Action	Description
1-1	092900	DELETE	Deleted all references to Level 5 finish
1-2	260500	REMOVE	Removed 1.3.D.2-3.
1-3	260500	REMOVE	Removed 1.9.1 260513 Wire and Cable.
1-4	260500	REMOVE	Removed 1.9.1 260520 Grounding and Bonding.
1-5	260500	REMOVE	Removed 1.9.1 260533 Conduit and Boxes.
1-6	260500	REMOVE	Removed 1.9.1 260553 Electrical Identification.
1-7	260513	REMOVE	Removed 1.1 D-G.
1-8	260513	REMOVE	Removed 1.4 Submittals.
1-9	260513	REMOVE	Removed 2.1.I.
1-10	260513	REMOVE	Removed 2.4.
1-11	260513	REMOVE	Removed 2.5.
1-12	260513	REMOVE	Removed 2.6.
1-13	260513	REMOVE	Removed 3.1.A.2.
1-14	260513	ADD	Added 3.1.A.2-4.
1-15	260513	REMOVE	Removed 3.1.D.
1-16	260513	REMOVE	Removed 3.8 AC, MC Cable Installation.
1-17	260535	REMOVE	Removed 1.1 C-F.
1-18	260535	REMOVE	Removed 2.3.
1-19	260535	REMOVE	Removed 2.4.
1-20	260535	REMOVE	Removed 2.5.
1-21	260535	REMOVE	Removed 2.6.
1-22	260535	REMOVE	Removed 3.3.
1-23	260535	REMOVE	Removed 3.4.
1-24	260553	REMOVE	Removed 1.4 Submittals.
1-25	260553	REMOVE	Removed 3.7 D.1.
1-26	260933	REMOVE	Removed 1.2.A.1 and 1.2.A.3.
1-27	260933	REMOVE	Removed 1.9.D.
1-28	260933	REMOVE	Removed 1.10: Mockup and Samples of Submitted Devices.
1-29	260933	REMOVE	Removed 2.2.A.1.
1-30	260933	ADD	Added 2.2.A.1.
1-31	260933	REMOVE	Removed 3.1 Pre-construction meeting.
1-32	260933	REMOVE	Removed 3.4.D Training.
1-33	260933	REMOVE	Removed 3.5 System Commissioning.
1-34	262726	REMOVE	Removed 1.1 B, D-K.
1-35	262726	REMOVE	Removed 1.5 C.
1-36	265119	REMOVE	Removed 1.4.D.

1-37	270526	REMOVE	Removed specification section in its entirety.
1-38	270500	REMOVE	Removed Section 1.2, D, 1. f.
1-39	270500	REMOVE	Removed Section 1.4, E, 4.
1-40	270500	REMOVE	Removed Section 1.7, A. 1 -27 05 03
1-41	270500	REMOVE	Removed Section 1.8 and 1.9
1-42	270500	REMOVE	Removed Section 3.9, C. 8.
1-43	271500	REMOVE	Removed Section 2.1, A. 8.
1-44	271500	REMOVE	Removed Section 2.1, B.
1-45	271500	REMOVE	Removed Section 2.2
1-46	271500	REMOVE	Removed Section 2.3, B
1-47	271710	REMOVE	Removed Section 2.1, A, b.
1-48	271720	REMOVE	Removed Section 1.2 B. and C.
1-49	271720	REVISE	Removed Section 2.1 TIA/EIA 568A to 568B.
1-50	283100	REMOVE	Removed 2.1.B.1.a.1.b.
1-51	283100	REMOVE	Removed 2.1.E – FA-210; Audio Horn Alarm.
			Devices: 1-5.
1-52	283100	REMOVE	Removed unutilized number in list.

Heading Number 2 – Drawings

Item	Sheet	Action	Description
2-1	G-000	REVISE	Revised Notes to Bidders #3 regarding Allowances
2-2	D-111	CLARIFY	Clarified Demolition Keyed Note #D10 regarding floor boxes
2-3	A-001	CLARIFY	Clarified existing floor to ceiling height
2-4	A-801	REVISE	Revised headwall assembly to be provided by Contractor
2-5	P201	ADD	Added medical gas outlet callout for each Headwall.
2-6	P600	REVISE	Revised headwall description.
2-7	P600	ADD	Added medical gas outlet group description to material list.
2-8	P600	ADD	Added outlet types and description to material List.
2-9	E001	REVISE	Revised lighting controls.
2-10	E001	ADD	Added switching label to symbols legends.
2-11	E001	REVISE	Revised luminaire schedule misspelling and redundant information.
2-12	E101	REVISE	Revised keynote tag and tag type.
2-13	E101	ADD	Added keynote tags.
2-14	E101	ADD	Added ceiling tag to receptacle for location Identity.
2-15	E201	ADD	Added Keynote 16.
2-16	E201	REVISE	Revised keynote and keynote tags.
2-17	E201	ADD	Added representation of surface mounted Raceway.
2-18	E201	ADD	Added circuit tag to a camera receptacle missing tag.
2-19	E201	ADD	Added keynote tags.
2-20	E201	ADD	Added lighting controls to computer Lab 118.
2-21	T000	REMOVE	Removed AV functional diagram key.
2-22	T000	ADD	Added applicable codes.
2-23	T101	REVISE	Revised clouded details on sheet.

2-24	T101	ADD	Added sheet notes 1 and 2.
2-25	T201	REVISE	Revised keynote 2.
2-26	T201	REVISE	Revised clouded details on sheet
2-27	T201	REMOVE	Removed two data outlets for wall mounted monitors. These are rough-ins that are shown on the electric set.
2-28	T400	REMOVE	Removed sheet in its entirety, details were not applicable.
2-29	T600	REMOVE	Removed CJ6X8TP and F-Connector CMFAW from equipment list

Heading Number 3 – Notifications

3-1	N/A
-----	-----

END OF ADDENDUM 03.